

Bidding Requirements, Contract Forms and Conditions of the Contract
ADDENDUM
Section 00900

ADDENDUM No. 5

Date February 12, 2013

City of Austin

Project Name North Acres Trail Improvements

C.I.P. No. 5771.025

This Addendum forms a part of Contract and clarifies, corrects or modifies original Bid Documents, dated December 31, 2012. Acknowledge receipt of this addendum in space provided on bid form. Failure to do so may subject bidder to disqualification.

A. Project Manual Revisions:

None

B. Drawing Revisions:

Sheet 6 of 26, Abutment and Bridge Specifications, Section 5800, Pre-fabricated Steel Bridge:

Add "Note 14. The bridge manufacturer shall provide location and connection details for bridge illumination per Key Notes 3 and 8 on Sheet 24 of 26."

Sheet 24 of 26, Electrical One-Line Diagram:

Change Panelboard Tag Number from "CEB-LP-001" to "NA-LP-001."


Change third line of panelboard description from "3Ø, 4W" to "1Ø, 3W."

This addendum consists of 1 page(s)/sheet(s).


Approved by OWNER


Approved by ENGINEER/ARCHITECT

END



2/12/2013